



NOTES:

- 1. Height above sea level of the escalator place should not be higher than 1000m. In case of doubt, please contact MP.
- 2. If one of the following situations, the dimensions marked with * shall be extended 500mm: (1) Double drive.
- (2) VVVF.
- (3) 220V and power exceeds 7.5 kW.
- 3. Client should provide the intermediate support base, which can be made of reinforced concrete or metallic structure in right position, in case of horizontal distance L higher than 15m.
- The requirements of escalators and building interfaces must be according with the national standards (EN115-1:2008+A1:2010). In case of doubt, please contact MP.